

Collins Architectural Group, p.s.
950 12th Avenue, Suite 200
Longview, WA 98632

Addendum No. 1

Page No. 1 of 1

Date: September 22, 2021

**Project: Kelso Housing Authority
KHA Water Line Replacement
Kelso, WA**

Notice to Contractor:

The following changes in the Contract Documents, including the Drawings and Specifications, constitute this Addendum. All changes included in Addenda shall become a part of the Contract Documents for this Project. Any changes herein offset only the specific Drawings or Notes on Drawings or words or paragraphs in Specifications referenced to and the balance of the Drawings shall remain in full force.

ARCHITECTURAL SPECIFICATION

<u>ITEM</u>	<u>SHEET NO./ SECTION NO.</u>	<u>DESCRIPTION</u>
1.0	A3.0	Install 1" PEX for the main water lines from the meter and 3/4" PEX lines from the main line to the buildings.
1.1	A3.0	Each building (duplexes) has two full bathrooms and two utility/laundry rooms.
1.2	Locating Services	It is the contractor's responsibility to hire a locating service to locate existing utilities.